

# TEST CERTIFICATE

for determination of slip resistance  
according to DIN EN 16165, Annex B

Tested material: **Wood/wood composite material**

Material type (wood): Oak parquet flooring with factory sealing  
Article description: BONA Traffic GO  
Dimensions: test sample: 1000 x 500 x 14 [mm]; parquet elements: variable length, thickness 14 mm; width/cover width: 20.5/19.8 [mm]  
Colour: oak / transparent  
Surface: matt, even, fine-rough structured  
test sample factory sealed with Bona Traffic GO (2-component; water-based polyurethane varnish); application quantity: 120 - 100 g/m<sup>2</sup>; double application structure: oak parquet + 1x Bona Primer + 2 Bona Traffic GO matt  
Producer/Supplier: Bona Sweden AB  
Murmansgatan 130  
200 21 Malmö  
SWEDEN

Client: Bona AB  
Murmansgatan 130  
212 25 Malmö  
SWEDEN

Certificate No.: 104872506.001e

Sample receipt: 25.07.2025

Test date: 29.07.2025

Sampling: Sent by the customer to the research institute

Test method: **DIN EN 16165** (edition 02/2023)  
"Determination of slip resistance of pedestrian surfaces - Methods of evaluation"  
**Annex B – Shod ramp test**  
The sample covering was delivered in a condition ready for testing.  
Test direction parallel to the plank length/grain.

Test result: Angle value  $\alpha_{shod}$ : **7°**

Assessment: **slip resistance class: R9**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 01.09.2025  
Schu/ke

This test certificate is only valid for the above-mentioned test material.  
The test certificate is issued for a period of 5 years (based on the test date).  
The statement of conformity is based on the binary decision rule according to "ILAC-G8: 09/2019".  
Publication and reproduction of the test certificate is only permitted in unabridged form.



– Institut für Wand- und Bodenbeläge –  
**SÄUREFLIESNER-VEREINIGUNG E.V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de

