

TEST CERTIFICATE

for the slip resistance of floor coverings
according to DIN EN 16165, Annex B

Tested material: **elastic covering**

Article description: BONA PURE HD extra matt
Material type: Elastic floor covering (PVC) with factory coating
Dimensions: 1000 x 500 x 3 [mm]
Colour: green
Surface: even, fine rough textured, matt
Producer/Supplier: Bona AB
Murmansgatan 130
212 25 Malmö
SWEDEN

Client: Bona AB
Murmansgatan 130
212 25 Malmö
SWEDEN

Certificate No.: 103052403.001e

Sample receipt: 06.08.2024

Test date: 22.08.2024

Sampling: Sent by the customer to the research institute


Test method: **DIN EN 16165** (edition 02/2023)
"Determination of slip resistance of pedestrian surfaces - Methods of evaluation"
Annex B – Shod ramp test
The test material was delivered in a ready-to-test surface condition.

Test result: Angle value α_{shod} : **8°**

Assessment: **slip resistance class: R9**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director


Dipl.-Ing. Friedrich Höltkemeyer



Großburgwedel, 27.08.2024
Schu/ke

This test certificate is only valid for the above-mentioned test material.
The test certificate is issued for a period of 5 years (based on the test date).
The statement of conformity is based on the binary decision rule according to "ILAC-G8: 09/2019".
Publication and reproduction of the test certificate is only permitted in unbridged form.



– Institut für Wand- und Bodenbeläge –

SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkKS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

